

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod litem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1050997

Product: Current discharge gap

Type: MCD 50-B, MC 50-B

Rating: $U_n=230\text{ V}/50\text{-}60\text{ Hz}$, $U_p<2\text{ kV}$, $U_c=225\text{ V AC (MC50-B)}$, $I_{imp}(10/350)=50\text{ kA}$, $U_p<1,3\text{ kV}$, $U_c=230\text{ V AC}$

Ordering firm: OBO Bettermann Praha s. r. o.
Modletice 81, 251 01 Říčany u Prahy, Czech Republic

Manufacturer: OBO Bettermann GmbH + Co.KG
Hütinger Ring 52, Menden D-58694, Germany

Trade mark:

The test results are stated in the test-report No.: 503271-01/01 of: 19.09.2005

A sample of the product was found to be in conformity with:
ČSN EN 61643:03

The validity of the certificate is limited to: 30.9.2008

6.10.2005

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



* C E R / 1 0 5 0 9 9 7 *

503271-01